



VEOLIA WATER NORTH AMERICA
303 Oak Hill Way
Brockton, MA 02301

Tel.: 508-580-7885 X 112
Fax: 508-559-0760

Fax

TO : Joseph Shepherd / David Burns, **Steve Couto**
FAX: 508-947-6557 617-918-1810
FROM : James Lauzon
DATE : October 6, 2004
SUBJECT : Notice of Violation
PAGES : 2

including this page

Please see the attached. Thanks

THIS TRANSMISSION CONTAINS CONFIDENTIAL INFORMATION INTENDED FOR USE ONLY BY THE ABOVE NAMED RECIPIENT. READING, DISCUSSION, DISTRIBUTION, OR COPYING OF THIS MESSAGE IS STRICTLY PROHIBITED BY ANYONE OTHER THAN THE NAMED RECIPIENT OR HIS OR HER EMPLOYEES OR AGENTS. IF YOU HAVE RECEIVED THIS FAX IN ERROR, PLEASE IMMEDIATELY NOTIFY US BY TELEPHONE (COLLECT), AND RETURN THE ORIGINAL MESSAGE TO US AT THE ABOVE ADDRESS VIA U.S. POSTAL SERVICE.





Date: 10/6/2004

Joseph J. Shepherd
Department of Environmental Protection
Southeast Region
20 Riverside Drive
Lakeville, MA 02347

Subject: Brockton Wastewater Treatment Facility
Notification of Unauthorized Discharge or Bypass Report/Notification of Permit
Exceedence

Dear Mr. Shepherd:

In accordance with Department of Environmental Protection policy, we are formally providing
required written notification of the following:


- ☐ 1. Notification of Unauthorized Discharge or Bypass Report
☒ 2. Notification of Permit Exceedence

The following notification has been made:

	<u>Person Contacted</u>	<u>By Email</u>	<u>Date/Time</u>	<u>By Fax</u>	<u>Date/Time</u>
MADEP	Joseph Shepherd	X	10/6/04 1:25pm	X	10/6/04 1:35pm
	David Burns	X	10/6/04 1:25pm		
EPA	Steven Couto			X	10/6/04 1:35pm

Description and cause of noncompliance: Ammonia Nitrogen – Max. Daily 10/4 = 2.54 mg/l. (1.5 mg/l limit)

On Sunday October 3, 2004, there was a power failure. Upon restarting the blowers, we had difficulty getting adequate oxygen levels to one of the aeration basins. We lost the nitrifiers in one basin. On Tuesday, the ammonia levels coming out of that basin were back to normal.

By: James M. Lauzon 

Title: Project Manager

cc: Steven Couto, USEPA
David Burns, MADEP
David Norton, Brockton W&S Contract Admin.
Farzin Kiani, VVNA Business Manager

VEOLIA WATER NORTH AMERICA
303 Oak Hill Way Brockton, MA 02301
Tel 508-560-7885

